

Certificate of Qualification

Certificate: 1955405

Master Contract: 240594

Project: 1955405

Date Issued: January 17, 2008

Issued to: **Betenbender Manufacturing Inc.**
5806 Quality Ridge Road
Coggon IA 52218
U.S.A.

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: J.-C. Chow, Eng.

Authorized by: 
Hélène Vaillancourt
Operations Manager

PRODUCTS

CLASS 3211 09 - INDUSTRIAL CONTROL EQUIPMENT - Special (Custom) Industrial Control Assemblies
CLASS 3211 89 - INDUSTRIAL CONTROL EQUIPMENT - Special (Custom) Industrial Control Assemblies
- Certified to US Standards

Special industrial control assemblies, enclosed, 600V max, 3-ph, 60Hz, 200A max input; outputs: 600V max, 3-ph, 60Hz, 200A/200hp total max (50hp max single motor starter); consisting of CSA Certified components such as enclosures, fuses, circuit breakers, direct or reduced motor starters or variable speed drives, contactors, transformers, control relays, timers, and auxiliary devices.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M91	-	General Requirements - Canadian Electrical Code, Part II
CSA-C22.2 No. 0.4-04	-	Bonding of Electrical Equipment
CAN/CSA-C22.2 No. 14-05	-	Industrial Control Equipment
UL 508A (First Edition)	-	Industrial Control Panels



Supplement to Certificate of Qualification

Certificate: 1955405

Master Contract: 240594

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1955405	January 17, 2008	Initial "cCSAus" Qualification. Special Industrial Control Assemblies, enclosed, 600Vac, 3-ph, 60Hz, 200A/200hp total max (50hp max single motor starter).